



# CERTIFICATE OF CONFORMITY

SAI Global hereby grants:

## Cromford Pipe

1 Douglas Road, MOSSVALE, NSW 2577, Australia

### WaterMark Certificate of Conformity – Level 1

Evaluated to:

**AS/NZS 4130:2003 - Polyethylene (PE) pipes for pressure applications**

“the WaterMark Licensee” the right to use or arrange the use of the WATERMARK as shown below only in respect of the goods described and detailed on the product schedule identified on [www.saiglobal.com](http://www.saiglobal.com) which are produced by the WaterMark Licensee or on behalf of the WaterMark Licensee\* and which comply with the appropriate Standard referred to above as from time to time amended. The Licence is granted subject to the rules governing the use of the WATERMARK and the Terms and Conditions for certification. The WaterMark Licensee covenants to comply with all the Rules and Terms and Conditions

**Certificate No:** WMKA20550-1

**Issued :** 14 April 2010

**Expires :** 16 December 2013

**Originally Certified :** 17 December 2008

**Current Certification :** 17 December 2008

Duncan Lilley  
Global Head – Assurance Services

Alex Ezrakhovich  
General Manager – Certification Services



**WaterMark**



[WWW.JAS-ANZ.ORG/REGISTER](http://WWW.JAS-ANZ.ORG/REGISTER)

\* For details of manufacture, refer to the licensee

The WATERMARK is a registered certification trademark of Standards Australia Limited (ACN 087 326 690) and is issued under licence by SAI Global Certification Services Pty Limited (ACN 108 716 669) (“SAI Global”) 286 Sussex Street, Sydney NSW 2000, GPO Box 5420 Sydney NSW 2001. This certificate remains the property of SAI Global and must be returned to SAI Global upon its request. Refer to [www.saiglobal.com](http://www.saiglobal.com) for the list of product models.



INFORM. INSPIRE. IMPROVE.

# SCHEDULE TO CERTIFICATE OF CONFORMITY

SAI Global hereby grants :

## Cromford Pipe

1 Douglas Road, MOSSVALE, NSW 2577, Australia

### WaterMark Certificate of Conformity – Level 1

Evaluated to:

**AS/NZS 4130:2003 - Polyethylene (PE) pipes for pressure applications**

Model identification of the goods on which the WATERMARK may be used:

Product Type	Product Application	Nominal Size (DN)	Pressure Classification (PN)	SDR	Pipe Series	Colour/Striping/Jacket	Compound Designation	Date Endorsed
Polyethylene (PE) Pressure Pipe	Water, Gas, Sewer	225	4, 6.3, 8, 10, 12.5, 16, 20, 25	41, 26, 21, 17, 13.6, 11, 9, 7.18	1 and 2	Black with blue, or yellow, lilac, beige stripe	PE 80/100	14 Apr 2010
Polyethylene (PE) Pressure Pipe	Water, Gas, Sewer	250	4, 6.3, 8, 10, 12.5, 16, 20, 25	41, 26, 21, 17, 13.6, 11, 9, 7.19	1 and 2	Black with blue, or yellow, lilac, beige stripe	PE 80/100	14 Apr 2010
Polyethylene (PE) Pressure Pipe	Water, Gas, Sewer	200	4, 6.3, 8, 10, 12.5, 16, 20, 25	41, 26, 21, 17, 13.6, 11, 9, 7.17	1 and 2	Black with blue, or yellow, lilac, beige stripe	PE 80/100	14 Apr 2010
Polyethylene (PE) Pressure Pipe	Water, Gas, Sewer	160	4, 6.3, 8, 10, 12.5, 16, 20, 25	41, 26, 21, 17, 13.6, 11, 9, 7.15	1 and 2	Black with blue, or yellow, lilac, beige stripe	PE 80/100	14 Apr 2010
Polyethylene (PE) Pressure Pipe	Water, Gas, Sewer	180	4, 6.3, 8, 10, 12.5, 16, 20, 25	41, 26, 21, 17, 13.6, 11, 9, 7.16	1 and 2	Black with blue, or yellow, lilac, beige stripe	PE 80/100	14 Apr 2010
Polyethylene (PE) Pressure Pipe	Water, Gas, Sewer	280	4, 6.3, 8, 10, 12.5, 16, 20, 25	41, 26, 21, 17, 13.6, 11, 9, 7.20	1 and 2	Black with blue, or yellow, lilac, beige stripe	PE 80/100	14 Apr 2010
Polyethylene (PE) Pressure Pipe	Water, Gas, Sewer	450	4, 6.3, 8, 10, 12.5, 16, 20, 25	41, 26, 21, 17, 13.6, 11, 9, 7.24	1 and 2	Black with blue, or yellow, lilac, beige stripe	PE 80/100	14 Apr 2010

**Certificate No:** WMKA20550-1

**Issued Date:** 14 April 2010

This schedule supersedes all previously issued schedules



\* For details of manufacture, refer to the licensee

The WATERMARK is a registered certification trademark of Standards Australia Limited (ACN 087 326 690) and is issued under licence by SAI Global Certification Services Pty Limited (ACN 108 716 669) ("SAI Global") 286 Sussex Street, Sydney NSW 2000, GPO Box 5420 Sydney NSW 2001. This certificate remains the property of SAI Global and must be returned to SAI Global upon its request. Refer to [www.saiglobal.com](http://www.saiglobal.com) for the list of product models.

# SCHEDULE TO CERTIFICATE OF CONFORMITY

Product Type	Product Application	Nominal Size (DN)	Pressure Classification (PN)	SDR	Pipe Series	Colour/Striping/Jacket	Compound Designation	Date Endorsed
Polyethylene (PE) Pressure Pipe	Water, Gas, Sewer	500	4, 6.3, 8, 10, 12.5, 16, 20, 25	41, 26, 21, 17, 13.6, 11, 9, 7.25	1 and 2	Black with blue, or yellow, lilac, beige stripe	PE 80/100	14 Apr 2010
Polyethylene (PE) Pressure Pipe	Water, Gas, Sewer	400	4, 6.3, 8, 10, 12.5, 16, 20, 25	41, 26, 21, 17, 13.6, 11, 9, 7.23	1 and 2	Black with blue, or yellow, lilac, beige stripe	PE 80/100	14 Apr 2010
Polyethylene (PE) Pressure Pipe	Water, Gas, Sewer	315	4, 6.3, 8, 10, 12.5, 16, 20, 25	41, 26, 21, 17, 13.6, 11, 9, 7.21	1 and 2	Black with blue, or yellow, lilac, beige stripe	PE 80/100	14 Apr 2010
Polyethylene (PE) Pressure Pipe	Water, Gas, Sewer	355	4, 6.3, 8, 10, 12.5, 16, 20, 25	41, 26, 21, 17, 13.6, 11, 9, 7.22	1 and 2	Black with blue, or yellow, lilac, beige stripe	PE 80/100	14 Apr 2010
Polyethylene (PE) Pressure Pipe	Water, Gas, Sewer	40	4, 6.3, 8, 10, 12.5, 16, 20, 25	41, 26, 21, 17, 13.6, 11, 9, 7.7	1 and 2	Black with blue, or yellow, lilac, beige stripe	PE 80/100	14 Apr 2010
Polyethylene (PE) Pressure Pipe	Water, Gas, Sewer	50	4, 6.3, 8, 10, 12.5, 16, 20, 25	41, 26, 21, 17, 13.6, 11, 9, 7.8	1 and 2	Black with blue, or yellow, lilac, beige stripe	PE 80/100	14 Apr 2010
Polyethylene (PE) Pressure Pipe	Water, Gas, Sewer	32	4, 6.3, 8, 10, 12.5, 16, 20, 25	41, 26, 21, 17, 13.6, 11, 9, 7.6	1 and 2	Black with blue, or yellow, lilac, beige stripe	PE 80/100	14 Apr 2010
Polyethylene (PE) Pressure Pipe	Water, Gas, Sewer	20	4, 6.3, 8, 10, 12.5, 16, 20, 25	41, 26, 21, 17, 13.6, 11, 9, 7.4	1 and 2	Black with blue, or yellow, lilac, beige stripe	PE 80/100	14 Apr 2010
Polyethylene (PE) Pressure Pipe	Water, Gas, Sewer	25	4, 6.3, 8, 10, 12.5, 16, 20, 25	41, 26, 21, 17, 13.6, 11, 9, 7.5	1 and 2	Black with blue, or yellow, lilac, beige stripe	PE 80/100	14 Apr 2010
Polyethylene (PE) Pressure Pipe	Water, Gas, Sewer	63	4, 6.3, 8, 10, 12.5, 16, 20, 25	41, 26, 21, 17, 13.6, 11, 9, 7.9	1 and 2	Black with blue, or yellow, lilac, beige stripe	PE 80/100	14 Apr 2010
Polyethylene (PE) Pressure Pipe	Water, Gas, Sewer	125	4, 6.3, 8, 10, 12.5, 16, 20, 25	41, 26, 21, 17, 13.6, 11, 9, 7.13	1 and 2	Black with blue, or yellow, lilac, beige stripe	PE 80/100	14 Apr 2010
Polyethylene (PE) Pressure Pipe	Water, Gas, Sewer	140	4, 6.3, 8, 10, 12.5, 16, 20, 25	41, 26, 21, 17, 13.6, 11, 9, 7.14	1 and 2	Black with blue, or yellow, lilac, beige stripe	PE 80/100	14 Apr 2010

**Certificate No:** WMKA20550-1

**Issued Date:** 14 April 2010

This schedule supersedes all previously issued schedules



**Registered by:**

The WATERMARK is a registered certification trademark of Standards Australia Limited (ACN 087 326 690) 286 Sussex Street, Sydney NSW 2000, GPO Box 5420 Sydney NSW 2001 and is issued under licence by SAI Global Certification Services Pty Limited (ACN 108 716 669) ("SAI Global") 286 Sussex Street, Sydney NSW 2000, GPO Box 5420 Sydney NSW 2001. This certificate remains the property of SAI Global and must be returned to SAI Global upon its request. Refer to [www.saiglobal.com](http://www.saiglobal.com) for the list of product models.

# SCHEDULE TO CERTIFICATE OF CONFORMITY

Product Type	Product Application	Nominal Size (DN)	Pressure Classification (PN)	SDR	Pipe Series	Colour/Striping/Jacket	Compound Designation	Date Endorsed
Polyethylene (PE) Pressure Pipe	Water, Gas, Sewer	110	4, 6.3, 8, 10, 12.5, 16, 20, 25	41, 26, 21, 17, 13.6, 11, 9, 7.12	1 and 2	Black with blue, or yellow, lilac, beige stripe	PE 80/100	14 Apr 2010
Polyethylene (PE) Pressure Pipe	Water, Gas, Sewer	75	4, 6.3, 8, 10, 12.5, 16, 20, 25	41, 26, 21, 17, 13.6, 11, 9, 7.10	1 and 2	Black with blue, or yellow, lilac, beige stripe	PE 80/100	14 Apr 2010
Polyethylene (PE) Pressure Pipe	Water, Gas, Sewer	90	4, 6.3, 8, 10, 12.5, 16, 20, 25	41, 26, 21, 17, 13.6, 11, 9, 7.11	1 and 2	Black with blue, or yellow, lilac, beige stripe	PE 80/100	14 Apr 2010

**End of Record**

**Certificate No:** WMKA20550-1

**Issued Date:** 14 April 2010

This schedule supersedes all previously issued schedules

**Registered by:**



The WATERMARK is a registered certification trademark of Standards Australia Limited (ACN 087 326 690) 286 Sussex Street, Sydney NSW 2000, GPO Box 5420 Sydney NSW 2001 and is issued under licence by SAI Global Certification Services Pty Limited (ACN 108 716 669) ("SAI Global") 286 Sussex Street, Sydney NSW 2000, GPO Box 5420 Sydney NSW 2001. This certificate remains the property of SAI Global and must be returned to SAI Global upon its request. Refer to [www.saiglobal.com](http://www.saiglobal.com) for the list of product models.