

Statement of Maximum Pipe Temperature

Product: ISO Pipe Range

Date: 8th August 2013

Pipework Temperature	Maximum Hours per year
<80 °C	No Limits
80 – 99 °C	50
100 – 119 °C	37
120 – 139 °C	28
140 – 150 °C	21

Maximum hours per year is based on modelling of a typical domestic solar water heating system, with worst-case frequencies of extreme temperature.

The maximum hours reflect pipe temperatures at the collector outlet for Alice Springs (hottest climate and worst case) and an evacuated tube collector (highest temperature system).

Australia

DEKS Industries Pty Ltd
ABN 77 107 135 544
5/841 Mountain Highway
Bayswater VIC 3153 Australia
P: +613 8727 8800
info@deks.com.au

North America

DEKS North America Inc.
1890 Lyndon Blvd
Falconer
NY 14733, USA
P: +1 847 702 6512

Europe

DEKS Europe Limited
West End Trading Estate
Blackfriars Road
Nailsea, Bristol BS48 4DJ, UK
P: + 44 1275 858866
sales@deks.co.uk